

# 2006 Consumer Confidence Report

Water System Name: MD-58 Sierra Highlands Report Date: 6/5/07

*We test the drinking water quality for many constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2006.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** One deep well drawing from water-bearing rock fractures

**Name & location of source(s):** Well 1 is located within the Sierra Highlands maintenance district

**Drinking Water Source Assessment information:** A source water assessment was conducted for the Sierra Highlands well in July 2002. While no contaminants, other than the naturally-occurring manganese deposits, were found in excess of current MCLs, local septic systems were identified as having the potential for outside contamination. A copy of the complete assessment may be viewed at the Madera County Environmental Health Department, by visiting the State's website, [www.dhs.ca.gov/ps/ddwem/technical/dwp/source\\_info/source\\_index.htm](http://www.dhs.ca.gov/ps/ddwem/technical/dwp/source_info/source_index.htm), or by requesting a summary of the assessment from Environmental Health at (559) 675-7823.

**Time and place of regularly scheduled board meetings for public participation:** Meetings are held at 9:00 a.m. each Tuesday, except the fifth Tuesday of any month, at the Board of Supervisors Chambers: 200 W. 4<sup>th</sup> Street, Madera. Visit the County's website, [www.madera-county.com/supervisors/agenda.html](http://www.madera-county.com/supervisors/agenda.html) for a copy of the agenda.

*For more information, contact:* Linda Alexander Phone: (559) 675-7817

## **TERMS USED IN THIS REPORT:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S. Environmental Protection Agency.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variations and Exemptions:** Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (ug/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the state Department of Health Services (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

**Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.) 4	1*	More than 1 sample in a month with a detection	0	Naturally present in the environment

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (to be completed only if there was a detection of lead or copper in the last sample set)	No. of samples collected	90 <sup>th</sup> percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	5	<5	0	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	5	.22	0	1.3	0.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	5/06	13	13	none	none	Generally found in ground & surface water
Hardness (ppm)	5/06	151	151	none	none	Generally found in ground & surface water

\*Any violation of an MCL or AL is marked with an asterisk. Additional information regarding the violation is provided later in this report.

**TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Fluoride (ppm)	5/06	.3	.3	2.0	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Radium 228 (pCi/L)	2 & 5/06	1.25	1.22-1.28	5	(0)	Erosion of natural deposits
Uranium (pCi/L)	5/06	2.2	2.2	20	0.43	Erosion of natural deposits

**TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	5/06	2.7	2.7	500	N/A	Runoff/leaching from natural deposits; seawater influence
Color (Units)	5/06	5	5	15	N/A	Naturally-occurring organic materials
Iron (ppb)	5/06	270	270	300	N/A	Leaching from natural deposits; industrial wastes
Manganese (ppb)	5/06	191*	191	50	N/A	Leaching from natural deposits
Specific Conductance (micromhos)	5/06	304	304	1600	N/A	Substances that form ions when in water; seawater influence
Sulfate (ppm)	5/06	8.2	8.2	500	N/A	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	5/06	230	230	1000	N/A	Runoff/leaching from natural deposits
Turbidity (Units)	5/06	1.4	1.4	5	N/A	Soil runoff
Zinc (ppm)	5/06	0.06	0.06	5.0	N/A	Runoff/leaching from natural deposits; industrial wastes

\*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by

*Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

### **Summary Information for Contaminants Exceeding an MCL, MRDL, or AL, or a Violation of Any Treatment Technique or Monitoring and Reporting Requirement**

**\*Total Coliforms:** Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this is a warning of potential problems. In September there was a positive sample. This initiated treatment by chlorination of the system. Follow-up sampling confirmed the presence of total coliform bacteria in three more samples; however, increased sampling frequency for the remainder of September and October were negative for the bacteria. We were unable to determine the cause.

**\*Manganese:** Manganese was found at a level that exceeds the secondary MCL of 50 ppb. The high levels are due to leaching of natural deposits. Secondary standards have been set to protect against unpleasant aesthetic effects such as color, taste, odor, and the staining of plumbing fixtures (i.e., tubs and sinks) and clothing while washing. Violation of these standards does not pose a risk to public health and communities may decide whether or not to treat for them. At this time, there are no plans for construction of a manganese removal plant at Sierra Highlands.

### **In Conclusion...**

With the exception of the single violation for Total Coliforms in September, the Sierra Highlands system had no other primary violations. We're proud that your drinking water meets or exceeds all other Federal and State requirements. Though we've learned through our testing that some contaminants have been detected, the EPA has determined that your water IS SAFE at these levels.

We hope you find this report informative and helpful. Please call our office if you have questions. The County of Madera works continually to provide the best available water to every tap. We ask that you, our customers, help us protect our water resources. Water is the heart of our community, our way of life and our future.