



NOTES:

1. Good for installation with 3' min. and 12' max. cover. Otherwise see STD. DWG. S-5 at other depths. Requirement for concrete incasement may be waived subject to County Engineer approval when plans are submitted by a Registered Civil Engineer indicating no need for additional support.
2. PVC gravity sewer pipe shall conform to standard specifications.
3. * indicates relative density compaction.
4. All trenches shall have compaction tests at locations determined by Code Enforcement Department.
5. Payment for compaction test will be the responsibility of the contractor.
6. 2½' min. when under pavement.

Spec's By _____	COUNTY OF MADERA	Date 7-1-81
Drawn By <u>J. SHIELDS</u>	PIPE BEDDING & TRENCH BACKFILL	Scale NONE
APPROVED BY _____		Drawing No. S-7
REVISIONS	8/1/02	