



T.I. = 6.0

R-Value	AC-Thickness	AB-Thickness
55+	3"	3"
45-55	3"	5"
40-45	3"	6"
35-40	3"	7 1/2"
30-35	3"	8 1/2"
25-30	3"	9 1/2"
20-25	3"	10 1/2"
15-20	3"	11 1/2"
10-15	3"	12 1/2"
5-10	3"	13 1/2"
< 5	3"	14 1/2"

Minimum T.I. = 6.0

NOTES:

1. Center Line Stripe required
2. Dike required when grade exceeds 5%.
3. Copies of R-Value and compaction tests must be submitted to and reviewed by the Road Department for approval.
4. Where sidewalks are required, a concrete curb and gutter will be installed.

Spec's By _____

Drawn By J. SHIELDS

APPROVED BY _____

COUNTY OF MADERA

CLASS IV LOCAL ROAD

Date
1-27-00

Scale
NONE

Drawing No.
ST-6

REVISIONS 8/1/02 10/1/02