



NOTES:

1. Residential, minimum T.I. 5.0
2. Commercial and/or Industrial, minimum T.I. 6.0
3. Copies of R-Value and compaction tests must be submitted to and reviewed by the Road Department for approval.
4. Applicant shall submit T.I. calculations for for approval by the Road Department prior to base and pavement construction.

T.I. = 6.0

R-Value	AC-Thickness	AB-Thickness
55+	3"	3"
45-55	3"	5"
40-45	3"	6"
35-40	3"	7 1/2"
30-35	3"	8 1/2"
25-30	3"	9 1/2"
20-25	3"	10 1/2"
15-20	3"	11 1/2"
10-15	3"	12 1/2"
5-10	3"	13 1/2"
< 5	3"	14 1/2"

T.I. = 5.0

R-Value	AC-Thickness	AB-Thickness
55+	2 1/2"	2 1/2"
45-55	3"	3"
40-45	3"	3 1/2"
35-40	3"	4 1/2"
30-35	3"	5 1/2"
25-30	3"	6 1/2"
20-25	3"	7"
15-20	3"	8"
10-15	3"	9"
5-10	3"	10"
< 5	3"	10 1/2"

Spec's By _____

COUNTY OF MADERA

Date
1-27-00

Drawn By J. SHIELDS

CLASS V LOCAL ROAD

Scale
NONE

APPROVED BY _____

Drawing No.
ST-7

REVISIONS 8/1/02 10/1/02