



NOTES:

1. Shoring or tapered banks will be required for any trench 5' or more in depth.
2. In all cases a minimum of 3" of paving over 6" Class II A.B. or equivalent is required. Paving material to be the same as that removed. (New pavement to be 1" thicker than original).
3. Decomposed granite may not be used for back fill or pipe bedding.
4. Compaction tests by a certified lab will be required for all trench cuts or other excavation. Contractor to bear full expense of all testing.
5. Upper lift of new A.C. pavement shall contain aggregate of 1/2" max. size.

Spec's By _____	<b>COUNTY OF MADERA</b>	Date 12-24-81
Drawn By <u>J. SHIELDS</u>	<b>STREET EXCAVATION, BACK FILL &amp; SURFACE RESTORATION</b>	Scale NONE
APPROVED BY _____		Drawing No. ST-28
REVISIONS	8/1/02	