



- NOTE:
1. WATER MAIN SERVICE SADDLES SHALL BE OF BRONZE CONSTRUCTION. SINGLE STRAP PERMITTED FOR TAPS 1" AND SMALLER. DOUBLE STRAPS REQUIRED FOR TAPS LARGER THAN 1".
  2. USE "NEPTUNE" TRIDENT 8 WATER METER WITHOUT MAGNETIC HEAD. METER SHALL HAVE STANDARD REGISTER FOR DIRECT READING IN U.S. GALLONS WITH FLANGED ENDS.
  3. METERS FOR 1 1/2" SERVICES OR LARGER TO BE INSTALLED AT THE DISCRETION OF THE ENGINEERING DEPARTMENT.

Spec's By \_\_\_\_\_

Drawn By J. SHIELDS

APPROVED BY  
\_\_\_\_\_  
COUNTY ENGINEER

## COUNTY OF MADERA

### WATER SERVICE CONNECTION & METER BOX INSTALLATION WITHOUT CURB & GUTTER

Date  
1-4-99

Scale  
NONE

Drawing No.  
W-7B

REVISIONS 8/1/02